

# ATTESTATION OF CONFORMITY

Issued to: Havells India Ltd.  
ORG Towers, 2D, Sector 126, Noida Expressway, NOIDA - 201304, INDIA

For the product: PV Inverter

Trade name: **HAVELLS**

Type/Model: enviro GT i10000T, enviro GT i15000T  
enviro GT i17000T, enviro GT i20000T

Ratings: See Annex

Manufactured by: Havells India Ltd.  
ORG Towers, 2D, Sector 126, Noida Expressway, NOIDA - 201304, INDIA

Requirements: IEC 60255-27:2013 (Second Edition)

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 6066884.52.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 25 November 2019

Number: 6066884.03AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 2



Ratings of the test product:

enviro GT i10000T:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 15/15 A, Isc PV: 20/20 A

Output: 400V, 3/N/PE, 50/60 Hz, max 10000 VA, max 3x15 A

enviro GT i15000T:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 21/21 A, Isc PV: 27/27 A

Output: 400V, 3/N/PE, 50/60 Hz, max 15000 VA, max 3x22 A

enviro GT i17000T:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 21/21 A, Isc PV: 27/27 A

Output: 400V, 3/N/PE, 50/60 Hz, max 17000 VA, max 3x25 A

enviro GT i20000T:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 24/24 A, Isc PV: 30/30 A

Output: 400V, 3/N/PE, 50/60 Hz, max 20000 VA, max 3x29 A