

# ATTESTATION OF CONFORMITY

Issued to: Havells India Ltd.  
ORG Towers, 2D, Sector 126, Noida Expressway, NOIDA - 201304, INDIA

For the product: PV Inverter

Trade name: **HAVELLS**

Type/Model: enviro GT i20000TD, enviro GT i25000TD  
enviro GT i30000TD, enviro GT i33000TD

Ratings: See Annex

Manufactured by: Havells India Ltd.  
ORG Towers, 2D, Sector 126, Noida Expressway, NOIDA - 201304, INDIA

Requirements: IEC 60255-27:2013 (Second Edition)

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 6066884.53.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 25 November 2019

Number: 6066884.04AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu  
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 2



Ratings of the test product:

enviro GT i20000TD:

PV input: Max.1100 Vdc, MPPT voltage range: 230-960 Vdc, max 24/24 A, Isc PV: 30/30 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 20000 W, max 22000 VA, max 3x32 A

enviro GT i25000TD:

PV input: Max.1100 Vdc, MPPT voltage range: 230-960 Vdc, max 28/28 A, Isc PV: 35/35 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 25000 W, max 27500 VA, max 3x40 A

enviro GT i30000TD:

PV input: Max.1100 Vdc, MPPT voltage range: 230-960 Vdc, max 30/30 A, Isc PV: 37.5/37.5 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 30000 W, max 33000 VA, max 3x48 A

enviro GT i33000TD:

PV input: Max.1100 Vdc, MPPT voltage range: 230-960 Vdc, max 30/30 A, Isc PV: 37.5/37.5 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 33000 W, max 36300 VA, max 3x53 A