

ATTESTATION OF CONFORMITY

Issued to: Havells India Ltd.
ORG Towers, 2D, Sector 126, Noida Expressway, NOIDA - 201304, INDIA

For the product: PV Inverter

Trade name: **HAVELLS**

Type/Model: enviro GT i50KT, enviro GT i60KT, enviro GT i70KT

Ratings: See Annex

Manufactured by: Havells India Ltd.
ORG Towers, 2D, Sector 126, Noida Expressway, NOIDA - 201304, INDIA

Requirements: IEC 60255-27:2013 (Second Edition)

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 6066884.54.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 25 November 2019

Number: 6066884.05AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed Page 1 of 2

DEKRA Testing and Certification (Shanghai) Ltd.
3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Jing'an District, Shanghai 200436 China
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-certification.com

Ratings of the test product:

enviro GT i50KT:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 40/30/30 A, Isc PV: 48/36/36 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 50000 W, max 50000 VA, max 3x80 A

enviro GT i60KT:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 40/40/40 A, Isc PV: 48/48/48 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 60000 W, max 60000 VA, max 3x90 A

enviro GT i70KT:

PV input: Max.1000 Vdc, MPPT voltage range: 250-960 Vdc, max 40/40/40 A, Isc PV: 48/48/48 A

Output: 400V, 3/N/PE, 50/60 Hz, nominal 70000 W, max 75000 VA, max 3x90 A